



John Hoadley and Sons, Inc.

- Water Works Specialist-

FLOW TEST REPORT

672 Union Street
Rockland, MA. 02370
T: (781) 878-8098
F: (781) 878-5298

Town of: ROCKLAND, MA

Name of Applicant: BOHLER ENGINEERING Phone Number: 508-480-9900
Address: 352 Turnpike Rd City: SouthBorough State: MA
Date: 8/6/2018 Time of Test: 9:15AM
Location of Test: Wilson Street

Distance between Hydrant # 1 and Hydrant # 2 is feet.
Elevation of Hydrant # 1 Higher Elevation of Hydrant # 2 Lower
Coefficient: Size of Main : 10" AC Pond St 6" AC
6" AC Wilson St

Hydrant # 1 Static: 60 PSI Residual: 49 PSI
Location: 116 Pond Street (10" AC Main)
Manufacture/ Type of Hydrant : Mueller Size: 5 1/4" Year: 1997
Flow Hydrant # 2 Static: 64 PSI Residual: 30 PSI
Location: 152 Wilson Street (6" AC Main)
Manufacture/ Type of Hydrant : Mueller Size: 5 1/4" Year: 2012
Pitot Tube 920 GPM Time Flow: 2 Minutes
Flow

Test Conducted by: Mike MacInnis & Trevor Berry

Inspector or Witness of Flow Test : Bill Royal